

Monday, July 15, 2019

Tim Grossi
Contoocook Valley School District
106 Hancock Road
Peterborough NH 03458

Project Name: Conval High School

Lab ID: 19060237

Project #: N/A

Date Received: 6/24/2019

Project Location: SCH-22290

Control #: 19060237

Dear Tim Grossi

Enclosed please find the laboratory results for the above referenced samples that were received by the ChemServe sample custodian on the above referenced date. Any abnormalities to the samples upon receipt would be noted on the enclosed chain of custody document. This report is not valid without a completed chain of custody with the corresponding control number, attached.

All samples analyzed by ChemServe are subject to quality standards. These standards are as stringent or more stringent than those established under NELAC, 40 CFR Part 136, state certification programs, and corresponding methodologies. ChemServe has a written QA/QC Procedures Manual that outlines these standards, and is available for your reference, upon request. Unless otherwise stated on the Chain of Custody or within the report, all holding times, preservation techniques, container types, and analytical methods are analogous with those outlined by NELAC. All units are based on "as received" weight unless denoted "dry".

Residual chlorine, sulfite and pH are intended to be performed as an immediate field analysis. Should any of these analyses be performed in the lab instead of in the field it will result in those analyses being performed out of holding time.

Acrolein and 2-chloroethylvinyl ether require an additional analysis with an un-preserved sample. If unpreserved vials were not submitted for these additional analysis then acrolein and 2-CEVE are reported as estimated due to not meeting method requirements for EPA 624.1 or EPA 524.2.

I certify that I have reviewed the above referenced analytical data and state forms, and I have found this report within compliance with the procedures outlined within NELAC. ChemServe's certified parameter list can be found at <http://www.chemservelab.com/Laboratory-Information-and-Documentation.aspx>



Jay Chrystal - President/Laboratory Director



Contoocook Valley School District

Tim Grossi

106 Hancock Road

Peterborough NH 03458

Control #: 19060237

Project Number: N/A

Project Name: Conval High School

Project Location: SCH-22290

Lab ID: 19060237

Date: 7/15/2019

Lab ID: 19060237

Sample Receiving and Comment Summary

Were samples submitted with a chain of custody?	Yes
Do all samples received match the chain of custody?	Yes
Were all samples received within applicable holding times?	Yes
Were all containers intact when received?	Yes
Were samples for volatile organic analysis free of headspace (per method)?	N/A
Was there evidence of cooling if not submitted the same day as sampling?	Yes
If the sample pH was not correct was it adjusted where applicable?	Yes
Were samples for dissolved metals already filtered by the client or field sampling?	N/A
Were Samples for O-phos filtered in the field?	N/A
Were samples received in the appropriate containers?	Yes
Where applicable; were chemical and micro samples received at correct temps.	No

Sample	Method	Client Identity	Matrix	Analyst
19060237-001	EPA 200.5 Rev 4.2	100 teachers rm bath N	Drinking Water	CharleneF

Comment: no comment

* Blank comment sections denote "No Comment"

Contocook Valley School District

Tim Grossi
106 Hancock Road
Peterborough NH 03458

Control #: 19060237
Project Number: N/A
Project Name: Conval High School
Project Location: SCH-22290

Analytical Results

Lab ID: 19060237
Date: 7/15/2019

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-001	EPA 200.5 Rev 4.2	100 teachers rm bath N		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:07:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-002	EPA 200.5 Rev 4.2	100 teachers rm bath S		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:08:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-003	EPA 200.5 Rev 4.2	100 ft Bys sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:12:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-004	EPA 200.5 Rev 4.2	100 ft Grls sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:14:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN



317 Elm Street
 Milford, NH 03055
 (603) 673-5440
 Sales@chemservelab.com

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-005	EPA 200.5 Rev 4.2	100 rgt Bys sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:15:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-006	EPA 200.5 Rev 4.2	100 rgt Grls sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:19:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-007	EPA 200.5 Rev 4.2	100 sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:18:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-008	EPA 200.5 Rev 4.2	101 E wall sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:05:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-009	EPA 200.5 Rev 4.2	101 Hall outside room 101		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:07:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-010	EPA 200.5 Rev 4.2	101 Instructors sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 8:58:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-011	EPA 200.5 Rev 4.2	101 N wall 2nd from left		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:00:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-012	EPA 200.5 Rev 4.2	101 N wall 3rd from left		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:01:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-013	EPA 200.5 Rev 4.2	101 N wall left		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:58:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-014	EPA 200.5 Rev 4.2	101 N wall rgt sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:02:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-015	EPA 200.5 Rev 4.2	101 W wall counter sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:03:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-016	EPA 200.5 Rev 4.2	104 -101 sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:21:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-017	EPA 200.5 Rev 4.2	104 E wall sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:09:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.007 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-018	EPA 200.5 Rev 4.2	104 Instructors sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:09:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.007 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-019	EPA 200.5 Rev 4.2	104 N wall left		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:18:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-020	EPA 200.5 Rev 4.2	104 N wall Middle		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:19:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-021	EPA 200.5 Rev 4.2	104 N wall rgt		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:18:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-022	EPA 200.5 Rev 4.2	104 W wall left		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:15:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-023	EPA 200.5 Rev 4.2	104 W wall rgt		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:13:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-024	EPA 200.5 Rev 4.2	108 E wall sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:24:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-025	EPA 200.5 Rev 4.2	108 Instructors sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:24:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-026	EPA 200.5 Rev 4.2	108 N wall left		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:33:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-027	EPA 200.5 Rev 4.2	108 N wall rgt		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:34:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-028	EPA 200.5 Rev 4.2	108 W wall left		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:35:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.006 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-029	EPA 200.5 Rev 4.2	108 W wall rgt		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:35:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-030	EPA 200.5 Rev 4.2	110 - 108 prep sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:26:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-031	EPA 200.5 Rev 4.2	110 E wall sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:52:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.007 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-032	EPA 200.5 Rev 4.2	110 Instructors sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:35:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.004 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-033	EPA 200.5 Rev 4.2	110 S wall lft sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:36:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.005 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-034	EPA 200.5 Rev 4.2	110 S wall rgt sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:36:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.008 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-035	EPA 200.5 Rev 4.2	110 W wall counter sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:40:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.006 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-036	EPA 200.5 Rev 4.2	110 W wall Laundry sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:40:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.004 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-037	EPA 200.5 Rev 4.2	155 sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:45:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-038	EPA 200.5 Rev 4.2	157 N wall left		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:50:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-039	EPA 200.5 Rev 4.2	157 N wall Middle		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:49:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.173 mg/L		7/3/2019	0.003	BenN



317 Elm Street
 Milford, NH 03055
 (603) 673-5440
 Sales@chemservelab.com

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-040	EPA 200.5 Rev 4.2	157 N wall rgt		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:47:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.048 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-041	EPA 200.5 Rev 4.2	157 W wall left		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:51:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.249 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-042	EPA 200.5 Rev 4.2	157 W wall Middle		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:50:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.004 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-043	EPA 200.5 Rev 4.2	157 W wall rgt		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:50:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.452 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-044	EPA 200.5 Rev 4.2	158 handwash sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:45:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.008 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-045	EPA 200.5 Rev 4.2	200 lft sink Grls		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:54:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-046	EPA 200.5 Rev 4.2	200 lft sink Bys		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:52:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-047	EPA 200.5 Rev 4.2	200 N teachers bath rm 200		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:57:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.004 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-048	EPA 200.5 Rev 4.2	200 rgt sink Grls		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:54:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-049	EPA 200.5 Rev 4.2	200 rgt sink Bys		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:52:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-050	EPA 200.5 Rev 4.2	200 S teachers bath rm 200		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:57:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.004 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-051	EPA 200.5 Rev 4.2	202 Hall outside Guidance		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:09:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-052	EPA 200.5 Rev 4.2	211 Hall side wall		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:03:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.029 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-053	EPA 200.5 Rev 4.2	211 Instructors sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:04:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.028 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-054	EPA 200.5 Rev 4.2	211 Out side wall sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:03:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.005 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-055	EPA 200.5 Rev 4.2	212 Instructors sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:11:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.058 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-056	EPA 200.5 Rev 4.2	212 1ft sink hall side wall		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:12:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-057	EPA 200.5 Rev 4.2	212 1ft sink outside wall		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:15:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.013 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-058	EPA 200.5 Rev 4.2	212 Middle sink hall side wall		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:13:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.023 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-059	EPA 200.5 Rev 4.2	212 Middle sink outside wall		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:15:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.005 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-060	EPA 200.5 Rev 4.2	212 rgt sink hall side wall		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:14:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-061	EPA 200.5 Rev 4.2	212 rgt sink outside wall		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:16:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.004 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-062	EPA 200.5 Rev 4.2	310 sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 8:57:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-063	EPA 200.5 Rev 4.2	400 across from main off. snk Grls		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:24:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-064	EPA 200.5 Rev 4.2	400 across from main off. snk Bys		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:24:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-065	EPA 200.5 Rev 4.2	400 across from main off. snk HC		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:24:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-066	EPA 200.5 Rev 4.2	407 Sink in cabinet		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:30:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-067	EPA 200.5 Rev 4.2	408 Serv sink in cabinet		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:31:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.028 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-068	EPA 200.5 Rev 4.2	410 hall handicapped WF		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:40:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-069	EPA 200.5 Rev 4.2	410 hall sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:40:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.004 mg/L		7/3/2019	0.003	BenN



317 Elm Street
 Milford, NH 03055
 (603) 673-5440
 Sales@chemservelab.com

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-070	EPA 200.5 Rev 4.2	410 hall standard WF		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:40:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-071	EPA 200.5 Rev 4.2	410A lft sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:37:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-072	EPA 200.5 Rev 4.2	410A Middle sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:37:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-073	EPA 200.5 Rev 4.2	410A rgt sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:37:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-074	EPA 200.5 Rev 4.2	410B lft sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:39:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-075	EPA 200.5 Rev 4.2	410B Middle sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:39:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-076	EPA 200.5 Rev 4.2	410B rgt sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:34:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-077	EPA 200.5 Rev 4.2	411 in counter		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:45:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-078	EPA 200.5 Rev 4.2	412 ceramics 1st in frm dr		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:50:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.004 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-079	EPA 200.5 Rev 4.2	412 ceramics 2nd in frm dr		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:50:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN



317 Elm Street
 Milford, NH 03055
 (603) 673-5440
 Sales@chemservelab.com

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-080	EPA 200.5 Rev 4.2	412 ceramics backside of cntr		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:50:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-081	EPA 200.5 Rev 4.2	413 Dark RM lft sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:45:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.018 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-082	EPA 200.5 Rev 4.2	413 Dark RM rgt sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 10:47:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.016 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-083	EPA 200.5 Rev 4.2	422 in counter		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 2:03:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-084	EPA 200.5 Rev 4.2	467 BR		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 11:54:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN



317 Elm Street
 Milford, NH 03055
 (603) 673-5440
 Sales@chemservelab.com

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-085	EPA 200.5 Rev 4.2	467 Servsink in cabinet		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 11:54:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-086	EPA 200.5 Rev 4.2	469 BR		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 11:57:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-087	EPA 200.5 Rev 4.2	471 sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 11:57:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-088	EPA 200.5 Rev 4.2	480 Nurse's BR		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:00:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-089	EPA 200.5 Rev 4.2	480 Nurse's sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:00:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-090	EPA 200.5 Rev 4.2	650 upper Gym in counter		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:11:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-091	EPA 200.5 Rev 4.2	651 upper Gym in counter		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:11:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-092	EPA 200.5 Rev 4.2	AD's BR upper Gym sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:19:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-093	EPA 200.5 Rev 4.2	ATC Lobby snk in lobby BR		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 2:10:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-094	EPA 200.5 Rev 4.2	av RM off lbry Snk in cabinet		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 2:20:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN



317 Elm Street
 Milford, NH 03055
 (603) 673-5440
 Sales@chemservelab.com

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-095	EPA 200.5 Rev 4.2	back of Kit BR		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 2:03:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.013 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-096	EPA 200.5 Rev 4.2	back of Kit by elec rm sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 2:03:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.010 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-097	EPA 200.5 Rev 4.2	bck of Kit by sklt fill for stm kettle		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 2:02:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.007 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-098	EPA 200.5 Rev 4.2	boys tm RM upper Gym lft snk		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 11:58:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-099	EPA 200.5 Rev 4.2	boys team RM upper Gym rgt snk		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 11:58:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN



317 Elm Street
 Milford, NH 03055
 (603) 673-5440
 Sales@chemservelab.com

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-100	EPA 200.5 Rev 4.2	BR off of ESP entrance hall		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:23:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-101	EPA 200.5 Rev 4.2	ESP sink ESP Kit		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:26:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-102	EPA 200.5 Rev 4.2	ESP dish sink ESP Kit		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:20:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-103	EPA 200.5 Rev 4.2	ESP kitchenette S wall		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:26:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-107	EPA 200.5 Rev 4.2	ESP WF center of ESP		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:58:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-108	EPA 200.5 Rev 4.2	grls team RM upper Gym lft snk		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 11:54:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-109	EPA 200.5 Rev 4.2	grl's team RM upper Gym rgt snk		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 11:54:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-110	EPA 200.5 Rev 4.2	gym 2nd to lft bys sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:31:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-111	EPA 200.5 Rev 4.2	gym 2nd to lft grls sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:27:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-112	EPA 200.5 Rev 4.2	gym 3rd from lft bys sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:31:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-113	EPA 200.5 Rev 4.2	gym 3rd from lft grls sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:27:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-114	EPA 200.5 Rev 4.2	gym boys coach's bys BR		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:34:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-115	EPA 200.5 Rev 4.2	gym concession sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:01:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-116	EPA 200.5 Rev 4.2	gym girls coach's grls BR		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:52:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-117	EPA 200.5 Rev 4.2	gym lft Grls sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:26:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-118	EPA 200.5 Rev 4.2	gym lft Bys sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:44:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-119	EPA 200.5 Rev 4.2	Gym lobby lft bys sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:10:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-120	EPA 200.5 Rev 4.2	Gym lobby lft grls sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:11:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-121	EPA 200.5 Rev 4.2	Gym lobby Middle Bys sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:10:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-122	EPA 200.5 Rev 4.2	Gym lobby Middle grls sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:18:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN



317 Elm Street
 Milford, NH 03055
 (603) 673-5440
 Sales@chemservelab.com

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-123	EPA 200.5 Rev 4.2	Gym lobby rgt Byssink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:11:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-124	EPA 200.5 Rev 4.2	Gym lobby rgt grls sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:19:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-125	EPA 200.5 Rev 4.2	Gym lobby WF		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:22:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-126	EPA 200.5 Rev 4.2	gym lckr rm hall hndicppd WF		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:00:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-127	EPA 200.5 Rev 4.2	gym locker rm hall standard WF		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:00:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN



317 Elm Street
 Milford, NH 03055
 (603) 673-5440
 Sales@chemservelab.com

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-128	EPA 200.5 Rev 4.2	gym rgt bys sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:30:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-129	EPA 200.5 Rev 4.2	gym rgt grls sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:28:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-130	EPA 200.5 Rev 4.2	Upper Gym Hand Bottle Fill		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:03:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-131	EPA 200.5 Rev 4.2	hall outside rm 222 WF		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:49:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-132	EPA 200.5 Rev 4.2	Gym Hall WF Hand Bottle Fill		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:35:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN



317 Elm Street
 Milford, NH 03055
 (603) 673-5440
 Sales@chemservelab.com

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-133	EPA 200.5 Rev 4.2	158 BR Right		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:55:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-134	EPA 200.5 Rev 4.2	158 BR Left		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 9:52:00 AM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-135	EPA 200.5 Rev 4.2	Gym Lobby WF Bottle		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:23:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-136	EPA 200.5 Rev 4.2	Kit delivery RM utility sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:42:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-137	EPA 200.5 Rev 4.2	Kit delivery RM veg washing sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:49:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN



317 Elm Street
 Milford, NH 03055
 (603) 673-5440
 Sales@chemservelab.com

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-138	EPA 200.5 Rev 4.2	Kit dish washing RM bay sink lft fct		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:45:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-139	EPA 200.5 Rev 4.2	Kit dsh washing RM bay sink rgt fct		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:45:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-140	EPA 200.5 Rev 4.2	kit dish washing RM dish sprayer		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:46:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-141	EPA 200.5 Rev 4.2	kit outside dish wash RM wsh		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:47:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-142	EPA 200.5 Rev 4.2	Kit sink between fridge & ovens		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:48:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.004 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-143	EPA 200.5 Rev 4.2	Kit Sink middle of prep area		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:51:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-144	EPA 200.5 Rev 4.2	Kit Sink near door		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:51:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.005 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-145	EPA 200.5 Rev 4.2	life skills common BR		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:26:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-146	EPA 200.5 Rev 4.2	Life Skills Kit Sink near dw		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:27:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-147	EPA 200.5 Rev 4.2	outsde ESP hndicpped WF		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:58:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-148	EPA 200.5 Rev 4.2	outside ESP non handicpped WF		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:53:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-149	EPA 200.5 Rev 4.2	outside RM 554 sink in L BR		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:35:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-150	EPA 200.5 Rev 4.2	outside RM 554 sink in R BR		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:55:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-151	EPA 200.5 Rev 4.2	outside RM 554 WF		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:30:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-152	EPA 200.5 Rev 4.2	RM 450 2nd frm lft snk E-W bnk		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:18:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.008 mg/L		7/3/2019	0.003	BenN



317 Elm Street
 Milford, NH 03055
 (603) 673-5440
 Sales@chemservelab.com

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-153	EPA 200.5 Rev 4.2	RM 450 2nd to lft sink N-S bank		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:22:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-154	EPA 200.5 Rev 4.2	RM 450 3rd from lft snk E to W bnk		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:11:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-155	EPA 200.5 Rev 4.2	RM 450 3rd to lft sink N-S bank		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:23:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-156	EPA 200.5 Rev 4.2	RM 450 4th frm lft snk E-W bank		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:11:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.010 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-157	EPA 200.5 Rev 4.2	611 PE/Office BR		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:46:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-159	EPA 200.5 Rev 4.2	RM 450 BR sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:14:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-160	EPA 200.5 Rev 4.2	RM 450 laundry sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:14:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.017 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-162	EPA 200.5 Rev 4.2	RM 450 lft sink B N - S bank		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:22:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-163	EPA 200.5 Rev 4.2	RM 450 lft sink E to W bank		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:10:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.017 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-165	EPA 200.5 Rev 4.2	RM 450 Sink in patients BR		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:18:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN



317 Elm Street
 Milford, NH 03055
 (603) 673-5440
 Sales@chemservelab.com

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-166	EPA 200.5 Rev 4.2	Rm 551 sink in BR		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 1:32:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	0.005 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-167	EPA 200.5 Rev 4.2	telco RM sink		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 2:30:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-168	EPA 200.5 Rev 4.2	upper Gym handicapped WF		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:05:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-169	EPA 200.5 Rev 4.2	upper Gym standard WF		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:04:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-170	EPA 200.5 Rev 4.2	BR W Hll across frm Ct yrd		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 2:20:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Sample	Method	Client Sample Identity	Units	Matrix	Analyst
19060237-171	EPA 200.5 Rev 4.2	Gym Lobby WF Handi. Bott. Filler		Drinking Water	CharleneF

Start Date/Time Sampled: 6/24/2019 12:04:00 PM Composite End Date/Time:

Parameter	CAS Number	Result	Qualifier	Date/Time Analyzed	RDL	Analyst
Hot Plate Digestion				7/3/2019	0	harleneF
Lead	7439-92-1	< 0.003 mg/L		7/3/2019	0.003	BenN

Qualifier: Description:

- B- Method blank contaminated with target analyte.
- B1- BOD had total oxygen loss. Result reported as ">"the highest dilution.
- B2- BOD had no oxygen loss. Result reported as "<" the lowest dilution.
- G- Reporting limit elevated due to matrix interference.
- H- Method prescribed holding time exceeded.
- J- Indicates an estimated value. Value is less than the quantitation limit.
- IL- Internal Standard(s) recovery was low due to matrix. Result may be biased high.
- IH- Internal Standard(s) recovery was high due to matrix. Result may be biased low.
- LH- Laboratory control spike(s) was high. Results may be biased high.
- LL- Laboratory control spike(s) was low. Results may be biased low.
- MH- Matrix spike recovery high due to matrix. Results may be biased high.
- ML- Matrix spike recovery low due to matrix. Results may be biased low.
- N- Non-target compound. Reported as a TIC.
- NC- Spike recovery was not calculated due to the concentration of the analyte being >4 times the concentration of the spike added.
- R- RPD outside acceptable recovery limits.
- RO- Sample received out of holding time.
- SH- Surrogate recovery high due to matrix
- SL- Surrogate recovery low due to matrix
- U- BOD/CBOD blank had an oxygen depletion greater than the suggested amount of 0.200.
- V- Sample pH for analysis was not within the required range when checked at time of analysis.
- Z- Too numerous to count (TNTC)

An "A" in the result column on the report indicates absent for presence/absent bacteria and a "P" indicates present for presence/absent bacteria.

19060237 7/8/19

Monitoring Loc at/Identifier	Laboratory (Sample) Identifier	Sample Purpose	Field Activity Start Date	Field Activity Start Time	Sampler Individual Full Name	Sample Comments	Laboratory Identifier	Method	Test Method Reference	Analyst/Stat	First Draw	Substance/ Name	Sampler Comments
Sch-22290	19060237-001	Sample - Routine	6/24/19	07:07	JC	100 teachers rm bath N	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-002	Sample - Routine		07:08	JC	100 teachers rm bath S	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-003	Sample - Routine		07:12	JC	100 Hg Bys sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-004	Sample - Routine		07:14	JC	100 Hg Gals sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-005	Sample - Routine		07:18	JC	100 Hg Bys sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-006	Sample - Routine		07:19	JC	100 Hg Gals sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-007	Sample - Routine		07:19	JC	100 sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-008	Sample - Routine		07:25	JC	101 E wall sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-009	Sample - Routine		07:27	JC	101 Hall outside room 101	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-010	Sample - Routine		07:30	JC	101 Instruction sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-011	Sample - Routine		07:30	JC	101 N wall 2nd from left	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-012	Sample - Routine		07:31	JC	101 N wall 3rd from left	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-013	Sample - Routine		07:32	JC	101 N wall left	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-014	Sample - Routine		07:33	JC	101 N wall right sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-015	Sample - Routine		07:35	JC	101 W wall counter sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-016	Sample - Routine		07:35	JC	104 - 101 sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-017	Sample - Routine		07:39	JC	104 E wall sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-018	Sample - Routine		07:40	JC	104 Instruction sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-019	Sample - Routine		07:40	JC	104 H wall left	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-020	Sample - Routine		07:41	JC	104 H wall Middle	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-021	Sample - Routine		07:48	JC	104 H wall right	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-022	Sample - Routine		07:48	JC	104 W wall left	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-023	Sample - Routine		07:53	JC	104 W wall right	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-024	Sample - Routine		07:54	JC	100 E wall sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-025	Sample - Routine		07:54	JC	100 Instruction sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-026	Sample - Routine		07:55	JC	100 H wall left	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-027	Sample - Routine		07:59	JC	100 H wall right	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-028	Sample - Routine		07:55	JC	100 W wall left	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-029	Sample - Routine		07:55	JC	100 W wall right	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-030	Sample - Routine		07:56	JC	110 - 100 prep sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-031	Sample - Routine		07:58	JC	110 E wall sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-032	Sample - Routine		07:58	JC	110 Instruction sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-033	Sample - Routine		07:58	JC	110 E wall in sink-	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-034	Sample - Routine		07:58	JC	110 E wall right sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-035	Sample - Routine		07:58	JC	110 W wall counter sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-036	Sample - Routine		07:58	JC	110 W wall Laundry sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-037	Sample - Routine		07:58	JC	155 sink	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-038	Sample - Routine		07:58	JC	157 N wall left	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-039	Sample - Routine		07:58	JC	157 N wall Middle	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-040	Sample - Routine		07:58	JC	157 N wall right	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	
Sch-22290	19060237-041	Sample - Routine		07:58	JC	157 W wall left	1008	200.5 or 200.8	USEPA	WATER	Y	LEAD	

Requested By: [Signature]
 Date/Time: 6-24-19 1:50 PM

Received By Lab: [Signature]
 Date/Time: 6-24-19 1:50 PM

Requested By: [Signature]
 Date/Time: 6-24-19 1:50 PM

Sch-22290	19060237-042	Sample - Routine		0928	QC	157 W well Middle	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-043	Sample - Routine		0930	TC	157 W well top	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-044	Sample - Routine		0935	TC	158 handwash sink	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-045	Sample - Routine		0937	TC	200 th sink Gals	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-046	Sample - Routine		0950	TC	200 th sink Bys	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-047	Sample - Routine		0957	TC	200 N location built m 200	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-048	Sample - Routine		0959	TC	200 top sink Gals	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-049	Sample - Routine		0959	TC	200 top sink Bys	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-050	Sample - Routine		0957	TC	200 S location built m 200	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-051	Sample - Routine		1009	TC	202 Hall outside Glaziana	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-052	Sample - Routine		1009	TC	211 Hall side wall	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-053	Sample - Routine		1009	TC	211 Insulators sink	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-054	Sample - Routine		1005	TC	211 Old side wall sink	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-055	Sample - Routine		1011	TC	212 Insulators sink	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-056	Sample - Routine		1012	TC	212 Insulators sink	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-057	Sample - Routine		1015	TC	212 th sink outside wall	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-058	Sample - Routine		1015	TC	212 Middle sink hall side wall	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-059	Sample - Routine		1015	TC	212 Middle sink outside wall	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-060	Sample - Routine		1019	TC	212 top sink hall side wall	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-061	Sample - Routine		1016	TC	212 top sink outside wall	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-062	Sample - Routine		0957	TC	310 sink	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-063	Sample - Routine		1024	TC	400 access from main office sink Gals	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-064	Sample - Routine		1024	TC	400 access from main office sink Bys	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-065	Sample - Routine		1024	TC	400 access from main office sink HC	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-066	Sample - Routine		1030	TC	407 Sink in cabinet	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-067	Sample - Routine		1031	TC	408 Serv sink in cabinet	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-068	Sample - Routine		1030	TC	410 Hall handdispped VP	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-069	Sample - Routine		1040	TC	410 Hall sink	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-070	Sample - Routine		1037	TC	410 Hall standard VP	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-071	Sample - Routine		1037	TC	410A III sink	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-072	Sample - Routine		1037	TC	410A Middle sink	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-073	Sample - Routine		1037	TC	410A top sink	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-074	Sample - Routine		1039	TC	410B III sink	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-075	Sample - Routine		1039	TC	410B Middle sink	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-076	Sample - Routine		1039	TC	410B top sink	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-077	Sample - Routine		1045	TC	411 in counter	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-078	Sample - Routine		1050	TC	412 ceramic 141 in from door	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-079	Sample - Routine		1050	TC	412 ceramic 2nd in from door	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-080	Sample - Routine		1050	TC	412 ceramic backside of counter	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-081	Sample - Routine		1046	TC	413 Dark RM II sink	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-082	Sample - Routine		1047	TC	413 Dark RM top sink	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-083	Sample - Routine		1047	TC	422 in counter	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-084	Sample - Routine		1159	TC	467 BR	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD
Sch-22290	19060237-085	Sample - Routine		1159	TC	467 Serv sink in cabinet	1008	200.5 or 200.B	USEPA	WATER	Y	LEAD

Requisitioned By: *[Signature]* Date/Time: *6-20-19* Received By: *[Signature]* Date/Time: *6-24-19 15:20*

19060237 7/8/19

Sch-22290	Sample - Routine	6/21/19	1235	QC	1008	200.5 or 200.8 USEPA	WATER	Y	LEAD	
Sch-22290	Sample - Routine		1233	QC	1008	200.5 or 200.8 USEPA	WATER	Y	LEAD	
Sch-22290	Sample - Routine		1246	QC	1008	200.5 or 200.8 USEPA	WATER	Y	LEAD	
Sch-22290	Sample - Routine				1008	200.5 or 200.8 USEPA	WATER	Y	LEAD	
Sch-22290	Sample - Routine				1008	200.5 or 200.8 USEPA	WATER	Y	LEAD	
Sch-22290	Sample - Routine				1008	200.5 or 200.8 USEPA	WATER	Y	LEAD	
Sch-22290	Sample - Routine				1008	200.5 or 200.8 USEPA	WATER	Y	LEAD	
Sch-22290	Sample - Routine				1008	200.5 or 200.8 USEPA	WATER	Y	LEAD	
Sch-22290	Sample - Routine				1008	200.5 or 200.8 USEPA	WATER	Y	LEAD	
Sch-22290	Sample - Routine				1008	200.5 or 200.8 USEPA	WATER	Y	LEAD	

Fill - 132 19060237 7/8/19